

Toshiba G8000 Series UPS

Installation Planning Guide for 225kVA UPS

Standard System: 480V Input, 480Y/277V Output

General Mechanical Information		
Dimensions (W x D x H)	Weight	Approximate Full-Load Heat Loss
Inches	Lbs.	Btu/Hr
55.1 x 31.5 x 78.75	3,307	39,230

Primary AC Input (480V 3-Ph/3-W)					
Maximum Input Power Demand			External Overcurrent Protection	Suggested Minimum Feeder Wire Size (Per Phase)	Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit
kVA	PF	Amps	Amps	AWG or kcmil at 75° C Temp. Rating	Feet
225	>0.98	271	350 AT	(1) x 500 kcmil	530

Alternate (Bypass) AC Input (480V 3-Ph/4-W)					
Maximum Input Power Demand			External Overcurrent Protection	Suggested Minimum Feeder Wire Size (Per Phase)	Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit
kVA	PF	Amps	Amps	AWG or kcmil at 75° C Temp. Rating	Feet
225	0.8	271	350 AT	(1) x 500 kcmil	390

Battery Input (360VDC Nominal)				
Battery Capacity Required for Full Load Output	Maximum Discharge at FL Output	External Over-current Protection	Suggested Minimum Feeder Wire Size (Per Phase)	Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit
kWh	Amps DC	Amps	AWG or kcmil at 75° C Temp. Rating	Feet
191.5	665	700 AT	(2) x 500 kcmil	110

AC Output (480/277V 3-Ph/4-W)					
Rated Output Power			External Overcurrent Protection	Suggested Minimum Feeder Wire Size (Per Phase)	Suggested Maximum Feeder Length Using Min. Wire Size
kVA	PF	Amps	Amps	AWG or kcmil at 75° C Temp. Rating	Feet
225	0.8	271	350 AT	(1) x 500 kcmil	390

Important Notes:

- Maximum Current required at Primary AC Input based on full load output and maximum battery charging current.
- Output load conductors are to be installed in separate conduit from input conductors.
- Control wires and power wires are to be installed in separate conduits.
- Recommended AC input and output overcurrent protection based on continuous full load current per NEC.
- Wiring shall comply with all applicable national and local electrical codes.
- Grounding conductors to be sized per NEC Article 250-122. Neutral conductors to be sized per NEC Article 310.15.
 - Primary AC Input: 3 ϕ , 4-wire + ground.
 - Alternate AC Input: 3 ϕ , 4-wire + ground.
 - AC Output: 3 ϕ , 4-wire + ground.
 - DC Input: 2-wire (Positive/Negative) + ground.
- Nominal battery voltage based on the use of VRLA type batteries (2.0 volts/cell nominal).
- Maximum battery discharge current based on lowest permissible discharge voltage of 1.6 VPC.
- DC wires should be sized to allow not more than a 2-volt drop at maximum discharge current.
- Weights do not include batteries or other auxiliary equipment external to the UPS.
- Sizing calculations based on the following assumptions:
 - Not more than 3 current-carrying conductors installed in steel conduit in ambient temperature of 30 degrees C.
 - Temperature rating of conductors and terminals: 75 deg. C.
 - Feeder distance calculations based on NEC Tables 8 and 9 data, allowing for 2% AC voltage drop.
 - Reference: 1999 NEC Handbook. Consult latest edition of applicable national and local codes for possible variations.
- Ratings of wires and overcurrent devices are suggested minimums. Consult with a registered Professional Engineer within your local area for proper size selections.

TOSHIBA INTERNATIONAL CORP.

13131 West Little York Road
Houston, TX 77041
Telephone: (800) 231-1412
Fax: (713) 896-5212
Web Site: www.tic.toshiba.com