



Issued Date	5/11/2023	Transmit #	
Issued By	dschoeck	Issued Rev	

#### **TYPICAL MOTOR PERFORMANCE DATA**

Model: 0054XPEA44A-P

HP	kW	Pole	FL RPM	Frame	Voltage	Hz	Phase	FL Amps
5	3.7	4	1750	184TC	230/460	60	3	13.0/6.5
Enclosure	IP	Ins. Class	S.F.	Duty	NEMA Nom. Eff.	NEMA Design	kVA Code	Ambient (°C)
TEFC	56	F	1.15	CONT	89.5	В		40 C

Load	HP	kW	Amperes	Efficiency (%)	Power Factor (%)
Full Load	5.00	3.7	6.5	89.7	81.2
¾ Load	3.75	2.8	5.0	89.3	77.6
½ Load	2.50	1.9	4.0	87.6	69.1
¼ Load	1.25	0.9	2.8	81.7	51.1
No Load			2.7		
Locked Rotor			46		46.0

Torque								
Full Load	Locked Rotor	Pull Up	Break Down	Inertia				
(lb-ft)	(% FLT)	(% FLT)	(% FLT)	(lb-ft²)				
15.0	255	240	370	0.50				

Safe Stall	Safe Stall Time(s) Sound		Bearin	Approx. Motor Weight		
Cold	Hot	Pressure	Bearin	195	Approx. Motor Weight	
Colu	1100	dB(A) @ 1M	DE	NDE	(lbs)	
35	15	-	6306UU	6306UU		

\*Bearings are the only recommended spare part(s).

Tag:

Motor Options: Product Family:EQP Global Explosion Proof Mounting:C-Face Round,Shaft:T Shaft

Customer	
Customer PO	
Sales Order	
Project #	

All characteristics are av	All characteristics are average expected values.					
TOSHIBA INTERNATIONAL CORPORATION · HOUSTON, TEXAS U.S.A.						
Engineering	zxie	Doc. Written By	D. Suarez	Doc.# / Rev	MPCF-1119 / 0	
Engr. Date	7/19/2019	Doc. Approved By	M. Campbell	Doc. Issued	6/8/2011	



Issued Date	5/11/2023	Transmit #	
Issued By	dschoeck	Issued Rev	

#### **TYPICAL MOTOR PERFORMANCE DATA**

Model: 0054XPEA44A-P

HP	kW	Pole	FL RPM	Frame	Voltage	Hz	Phase	FL Amps
5	3.7	4	1430	184TC	190/380	50	3	16.6/8.3
Enclosure	IP	Ins. Class	S.F.	Duty	NEMA Nom. Eff.	NEMA Design	kVA Code	Ambient (°C)
TEFC	56	F	1.0	CONT	86.5	В		40 C

Load	HP	kW	Amperes	Efficiency (%)	Power Factor (%)
Full Load	5.00	3.7	8.3	86.4	79.0
¼ Load	3.75	2.8	6.5	87.7	74.6
½ Load	2.50	1.9	5.0	87.1	64.7
½ Load	1.25	0.9	4.0	81.1	43.3
No Load			3.8		
Locked Rotor			53	-	53.3

Torque								
Full Load	Locked Rotor	Pull Up	Break Down	Inertia				
(lb-ft)	(% FLT)	(% FLT)	(% FLT)	(lb-ft²)				
18.4	220	200	280	0.43				

Safe Stall	Safe Stall Time(s) Sound		Bearin	Approx. Motor Weight		
Cold	Hot	Pressure	Bearin	195	Approx. Motor Weight	
Colu	1100	dB(A) @ 1M	DE	NDE	(lbs)	
35	15	-	6306UU	6306UU		

\*Bearings are the only recommended spare part(s).

Motor Options: Product Family:EQP Global Explosion Proof Mounting:C-Face Round,Shaft:T Shaft

Customer	
Customer PO	
Sales Order	
Project #	

Tag:

All characteristics are average expected values.

TOSHIBA INTERNATIONAL CORPORATION · HOUSTON, TEXAS U.S.A.								
Engineering	garce	Doc. Written By	D. Suarez	Doc.# / Rev	MPCF-1119 / 0			
Engr. Date	6/5/2015	Doc. Approved By	M. Campbell	Doc. Issued	6/8/2011			




Issued Date	5/11/2023	Transmit #	
Issued By	dschoeck	Issued Rev	

### SPEED TORQUE/CURRENT CURVE

Model: 0054XPEA44A-P

HP	kW	Pole	FL RPM	Frame	Voltage	Hz	Phase	FL Amps
5	3.7	4	1750	184TC	230/460	60	3	13.0/6.5
Enclosure	IP	Ins. Class	S.F.	Duty	NEMA Nom. Eff.	NEMA Design	kVA Code	Ambient (°C)
TEFC	56	F	1.15	CONT	89.5	В		40 C
Looked Boton	Rotor wk <sup>2</sup>				Torque			
Locked Rotor Amps	Inertia	Full Load	Locked	Rotor	Pull Up		Break	Down
Allips	(lb-ft²)	(lb-ft)	(%	b)	(%)		(%	<b>%)</b>
46	0.50	15.0	25	5	240		37	70

# Design Values





Customer	wk² Load Inertia (lb	ft²) -
Customer PO	Load T	/pe -
Sales Order	Voltage	<b>(%)</b> 100
Project #	Accel. T	me -

Tag:

All characteristics are average expected values.

TOSHIBA INTERNATIONAL CORPORATION · HOUSTON, TEXAS U.S.A.								
Engineering	zxie	Doc. Written By	D. Suarez	Doc.# / Rev	MPCF-1121 / 0			
Engr. Date	7/19/2019	Doc. Approved By	M. Campbell	Doc. Issued	6/8/2011			




Issued Date	5/11/2023	Transmit #	
Issued By	dschoeck	Issued Rev	

### SPEED TORQUE/CURRENT CURVE

Model: 0054XPEA44A-P

HP	kW	Pole	FL RPM	Frame	Voltage	Hz	Phase	FL Amps
5	3.7	4	1430	184TC	190/380	50	3	16.6/8.3
Enclosure	IP	Ins. Class	S.F.	Duty	NEMA Nom. Eff.	NEMA Design	kVA Code	Ambient (°C)
TEFC	56	F	1.0	CONT	86.5	В		40 C
Locked Rotor	Rotor wk <sup>2</sup>				Torque			
Amps	Inertia	Full Load	Locked	Rotor	Pull Up	)	Break	Down
Allips	(lb-ft²)	(lb-ft)	(%	<b>6</b> )	(%)		(%	6)
53	0.43	18.4	22	0	200		28	30

# Design Values





Customer	wk² Load Inertia (lb	ft²) -
Customer PO	Load T	/pe -
Sales Order	Voltage	<b>(%)</b> 100
Project #	Accel. T	me -


Tag:

All characteristics are average expected values.

TOSHIBA INTERNATIONAL CORPORATION · HOUSTON, TEXAS U.S.A.								
Engineering	garce	Doc. Written By	D. Suarez	Doc.#/Rev	MPCF-1121 / 0			
Engr. Date	6/5/2015	Doc. Approved By	M. Campbell	Doc. Issued	6/8/2011			

# Motor Connection Diagrams 9 Leads

## Across-the-Line Starting / Running Connections



Switch L1 and L2 to reverse rotation

By: R. Murillo Date: 4/9/08 Checked: MDC Date: 5/17/11 Revision 0