

TOSHIBA INTERNATIONAL CORPORATION

3 PHASE INDUCTION MOTOR F1 ASSEMBLY

www.toshiba.com/ind



Issued Date	9/24/2019	Transmit #	
Issued By	dschoeck	Issued Rev	

## **TYPICAL MOTOR PERFORMANCE DATA**

Model: B2001FLG3BSHD

HP	kW	Pole	FL RPM	Frame	Voltage	Hz	Phase	FL Amps
200	150	2	3575	447TS	460	60	3	224
Enclosure	IP	Ins. Class	S.F.	Duty	NEMA Nom. Eff.	NEMA Design	kVA Code	Ambient (°C)
TEFC	56	F	1.15	CONT	95.8	В	G	40 C

Load	HP	kW	kW Amperes Efficiency (%)		Power Factor (%)
Full Load	200	149.1	223.8	95.9	87.2
¾ Load	150.00	111.9	174.1	95.2	84.7
½ Load	100.00	74.6	128.3	93.6	78.0
¼ Load	50.00	37.3	90.6	88.5	58.4
No Load			60.4		5.4
Locked Rotor	1		1450		36.0

Torque						
Full Load	Full Load Locked Rotor Pull Up Break Down					
(lb-ft)	(% FLT)	(% FLT)	(% FLT)	(lb-ft²)		
294	230	175	260	46.88		

Safe Stall	Stall Time(s) Sound		Bearin	uae*	Approx. Motor Weight	
Cold	Hot	Pressure dB(A) @ 1M	Bearings* DE NDE			
16.9	8.6	-	6313C3	6313C3	2408	

\*Bearings are the only recommended spare part(s).

Motor Options: Product Family:EQP Global 840 Mounting:Footed,Shaft:TS Shaft

Customer	
Customer PO	
Sales Order	
Project #	

Tag:

All characteristics are average expected values.

TOSHIBA INTERNATIONAL CORPORATION · HOUSTON, TEXAS U.S.A.								
Engineering	bmammen	Doc. Written By	D. Suarez	Doc.# / Rev	MPCF-1119 / 1			
Engr. Date	3/4/2015	Doc. Approved By	M. Campbell	Doc. Issued	9/20/2019			




Issued Date	9/24/2019	Transmit #	
Issued By	dschoeck	Issued Rev	

## SPEED TORQUE/CURRENT CURVE

Model: B2001FLG3BSHD

HP	kW	Pole	FL RPM	Frame	Voltage	Hz	Phase	FL Amps	
200	150	2	3575	447TS	460	60	3	224	
Enclosure	IP	Ins. Class	S.F.	Duty	NEMA Nom. Eff.	NEMA Design	kVA Code	Ambient (°C)	
TEFC	56	F	1.15	CONT	95.8	В	G	40 C	
Laskad Datas	Rotor wk²	_			Torque				
Locked Rotor Amps	Inertia	Full Load	Locked	l Rotor	Pull U	p	Break	Down	
Allips	(lb-ft²)	(lb-ft)	(%	<b>6</b> )	(%)		(%	<b>%</b> )	
1450	46.88	294	230		175	175		260	

## Design Values






Customer	wk² Load Inert	ia (lb-ft²)
Customer PO	Lo	ad Type -
Sales Order	Vo	tage (%) 100
Project #	Acc	el. Time -


Tag:

All characteristics are average expected values.

TOSHIBA INTERNATIONAL CORPORATION · HOUSTON, TEXAS U.S.A.								
Engineering	bmammen	Doc. Written By	D. Suarez	Doc.# / Rev	MPCF-1121/1			
Engr. Date	3/4/2015	Doc. Approved By	M. Campbell	Doc. Issued	9/20/2019			

## Motor Connection Diagram 3 Leads - Delta Connection





Switch L1 and L2 to reverse rotation

Each lead may consist of more than one cable. If multiple cables represent a single lead, each one of them will be labeled with the appropriate lead number.

By: R. Murillo Date: 4/9/08 Checked: MDC Date: 5/17/11 Revision 0